

SVENMIX INJECTION RING SPECIFICATIONS

1] The Injection Ring shall be constructed of Schedule 80 PVC. Connections shall be Flanged, MPT or FPT.

2] The Injection Ring shall have four injection ports sized to the required flow. The injection ports shall be spaced evenly around the diameter and each shall have a backflow check valve.

3] The Injection Ring may be mounted horizontally or vertically